



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>CAMBRIDGE GLEN</b>					DATE <b>7/22/2013</b>	SIGNATURE	
LOCATION <b>15955 LINDSEY RD, CHINO HILLS, CA 91710</b>					REINSPECTION DATE <b>1/22/2014</b>	PERMIT EXPIRATION <b>1/31/2014</b>	
MAILING ADDRESS <b>15955 LINDSEY RD, CHINO HILLS, CA 91710</b>					REHS <b>Tin Nguyen</b>		
FA # <b>FA0004986</b>	PR # <b>PR0015176</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Spa		
TIME IN <b>2:38 PM</b>	TIME OUT <b>3:04 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	101.0
observed flow (gpm)	50
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K462 Plumbing - Backflow Protection**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3141B, 3118B

**Inspector Comments:** Observed gap between sewer line and floor drain above 1 inch in pool/spa recirculation pump room. Ensure at least 1 inch gap is provided between sewer line and floor drain in pool/spa recirculation pump room.

**Violation Description:** There shall be no direct connection between any potable water supply system and the pool or its piping system unless protected by a backflow prevention device in accordance with Chapter 6 of the California Plumbing Code. There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system. Potable water outlets with hose attachments shall be protected by a nonremovable hose bibb backflow preventer, a nonremovable hose bibb vacuum breaker, or by an atmospheric vacuum breaker.

**36K466 Structure - Pool Shell**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3108B

**Inspector Comments:** Observed depth mark on waterline tiles in spa to be completely faded. Ensure depth mark on waterline tiles in spa is darkened and visible.

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

**36K472 Access - Steps - Handrails - Diving Area**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3111B, 3113B

**Inspector Comments:** Observed loose hand rail in spa. Tighten hand rail in spa.

**Violation Description:** Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.

**Overall Inspection Comments**

pH: 8.0  
Chlorine: 2.5 ppm  
CYA: 55 ppm  
Flow rate: 50 gpm

**Photo Attachments:**  
No Photo Attachments