



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|---------------------------------------|--|
| FACILITY NAME SUN-POINT VILLAGE APARTMENTS | | | | DATE 7/22/2013 | SIGNATURE |
| LOCATION 474 E WABASH, SAN BERNARDINO, CA 92404 | | | | REINSPECTION DATE 1/22/2014 | PERMIT EXPIRATION 5/31/2013 |
| MAILING ADDRESS 474 E WABASH, SAN BERNARDINO, CA 92404 | | | | REHS Marilyn Krichbaum | |
| FA # FA0005604 | PR # PR0013549 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: Pool |
| TIME IN 10:00 AM | TIME OUT 11:00 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 01 - No Further Action Required |

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

90

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | 40 |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

36K991 Permit Investigation

| | | |
|----------------------------|--------------------------------|--|
| POINTS NA | Compliance Date: Not Specified | Inspector Comments: Observed that the health permits for the pool and spa are delinquent. The amount owed is \$1,120.00. Delivered bill. Immediately pay this amount by thursday, 7-25-13, otherwise the pool and spa will be closed. Take payment to 385 N Arrowhead, 2nd floor, SB. |
| | Not In Compliance | |
| | Violation Reference - HSC | |

Violation Description: Obtain a valid health permit within 3 days or as specified to avoid facility closure and/or other possible legal action.

36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed no chlorine level in the pool. Immediately add chlorine. Maintain a chlorine level of 1.5ppm not to exceed 10ppm. Observed tablets in the chlorinator. Manager already has the pool closed. Call me for reinspection at 1-800-442-2283. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65529 | |

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

36K416 Water Quality - Non-Critical - Clarity

| | | |
|---------------------------|--|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed that the pool was very cloudy. Could not see the bottom drains. Immediately make the necessary repairs so that the pool is clear. Observed that the pool recirculation system was not operating long enough. The system must be operating as long as necessary(23 hours) to maintain clarity and chemistry. Pool is already closed by manager. Call me for reinspection. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65527, 65543 | |

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.

36K430 Safety - Equipment/First Aid Kit

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Immediately replace the missing 12ft rescue pole. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65539 | |

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | |
|---|----------------------------------|---------------|
| FACILITY NAME SUN-POINT VILLAGE APARTMENTS | DATE 7/22/2013 | SIGNATURE |
| LOCATION 474 E WABASH, SAN BERNARDINO, CA 92404 | REHS Marilyn Krichbaum | |

36K458 Maintenance - Test Kit/Daily Records

| | | |
|--|--------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Maintain a daily log of pool chlorine and ph levels. Observed no daily log. |
| | Not In Compliance | |
| Violation Reference - CCR - 65523, 65529 | | |

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

36K462 Plumbing - Backflow Protection

| | | |
|--|--------------------------------|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Replace the missing antisiphon device on the hose bib. |
| | Not In Compliance | |
| Violation Reference - CCR - 3141B, 3118B | | |

Violation Description: There shall be no direct connection between any potable water supply system and the pool or its piping system unless protected by a backflow prevention device in accordance with Chapter 6 of the California Plumbing Code.

There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system. Potable water outlets with hose attachments shall be protected by a nonremovable hose bibb backflow preventer, a nonremovable hose bibb vacuum breaker, or by an atmospheric vacuum breaker.

36K429 Safety - Notification - New Sign Requirements

| | | |
|--------------------------------------|--------------------------------|--|
| POINTS NA | Compliance Date: Not Specified | Inspector Comments: Provide the new pool safety signs: These signs must be in 4 inch lettering. Provide the Keep Closed sign on the exterior side of all gates. Provide the telephone number of the nearest emergency services such as the fire, ambulance, emt services. Provide the name and address of the facility in the pool area. The wording on the Warning No Lifeguard on Duty sign has changed. Provide the diarrhea warning sign on the gate or entrance area of the pool. This sign can be in 1 inch lettering. See handout. |
| | Not In Compliance | |
| Violation Reference - CCR 24 - 3120B | | |

Remove the unapproved diarrhea keep gate closed sign.

Replace the missing no diving allowed sign.

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

Identify the filters. Provide the direction of the flow of the water thru the entire recirculation system on the equipment by the use of arrows.

Photo Attachments:

No Photo Attachments