



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>STONERIDGE APARTMENTS</b>					DATE <b>7/18/2013</b>	SIGNATURE	
LOCATION <b>1540 W 8TH ST, UPLAND, CA 91786</b>					REINSPECTION DATE <b>8/01/2013</b>	PERMIT EXPIRATION <b>5/31/2014</b>	
MAILING ADDRESS <b>1540 W 8TH ST, UPLAND, CA 91786</b>					REHS <b>Jose Rodriguez</b>		
FA # <b>FA0008517</b>	PR # <b>PR0014474</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Office Spa SERVICE: 001 - Inspection - Routine		
TIME IN <b>1:43 PM</b>	TIME OUT <b>2:03 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 05 - Corrective Action / Follow up Required ACTION: 13 - Permit Suspended / Facility Closed		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**80**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:** Permit is suspended due to lack of chlorine in the spa. Contact Health Dept. when ready (800) 442-2283. Failure to correct violation by the re-inspection will result in further re-inspections charged at \$122.50 per 30 minutes.

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed 0 ppm of chlorine in the spa. Maintain chlorine levels between 1.5-10 ppm.

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed pH levels greater than 8.0. Maintain between 7.2-8.0 at all times.

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed cyanuric acid levels greater than 100 ppm. Maintain between 30-50 ppm.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>STONERIDGE APARTMENTS</b>	DATE <b>7/18/2013</b>	SIGNATURE
LOCATION <b>1540 W 8TH ST, UPLAND, CA 91786</b>	REHS <b>Jose Rodriguez</b>	

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Provide an air gap between wastewater pipe and sewer line to prevent potential backflow contamination.
	Violation Reference - HSC - 3120B, 3132B, 3141B	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed stuck flow meter. Repair/replace flow meter to give accurate readings to within 10% of the flow.
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K454 Maintenance - Cleanliness**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Clean/maintain spa shell. Observed debris/sand build-up.
	Violation Reference - CCR - 65533	

**Violation Description:** Floating scum, sputum or debris shall not be allowed to accumulate in the pool. The bottom and sides of the pool shall be cleaned as often as necessary to be kept in a clean condition. The sides and bottom of pools, decks and other surfaces shall be kept free of slime and algae.

**36K466 Structure - Pool Shell**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Re-plaster spa within 6 months. Observed bottom chipped and stairs chipped. Ensure that shell is smooth and non-abrasive.
	Violation Reference - CCR - 3108B	

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

**36K472 Access - Steps - Handrails - Diving Area**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed loose handrail in the deep end of the pool. Tighten handrail.
	Violation Reference - CCR - 3111B, 3113B	

**Violation Description:** Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>STONERIDGE APARTMENTS</b>	DATE <b>7/18/2013</b>	SIGNATURE
LOCATION <b>1540 W 8TH ST, UPLAND, CA 91786</b>	REHS <b>Jose Rodriguez</b>	

**36K429 Safety - Notification - New Sign Requirements**

<b>POINTS NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Ensure that facility provides the following signs for next pool season: Directional arrows demonstrating water flow, emergency number for the nearest fire department and diarrhea.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments