



**County of San Bernardino • Department of Public Health**  
**Division of Environmental Health Services**  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>29 PALMS R V &amp; GOLF RESORT</b>					DATE <b>7/23/2013</b>	SIGNATURE	
LOCATION <b>4949 DESERT KNOLL DR, TWENTYNINE PALMS, CA 92277</b>					REINSPECTION DATE <b>1/23/2014</b>	PERMIT EXPIRATION <b>11/30/2013</b>	
MAILING ADDRESS <b>4949 DESERT KNOLL AV, TWENTYNINE PALMS CA 92277</b>					REHS <b>Chaz Harrison</b>		
FA # <b>FA0004385</b>	PR # <b>PR0015320</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool		
TIME IN <b>1:31 PM</b>	TIME OUT <b>1:42 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K428 Safety - Safety Signs**

**POINTS**  
**2**

Compliance Date: **Not Specified**  
**Not In Compliance**  
 Violation Reference - **CCR 24 - 3120B**

**Inspector Comments:** Observed the following missing signs:

- KEEP CLOSED** - A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED" (3120B.10).
- DIARRHEA** - A sign in letters at least 1 inch (25 mm) high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water (3120B.11).

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**36K430 Safety - Equipment/First Aid Kit**

**POINTS**  
**2**

Compliance Date: **Not Specified**  
**Not In Compliance**  
 Violation Reference - **CCR - 65539**

**Inspector Comments:** Observed no rope attached to life ring. All swimming pools are required to provide a life ring with an outside diameter of 17 inches and a rope (at least 3/16 inches in diameter) attached that is long enough to span the widest part of the pool.

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>29 PALMS R V &amp; GOLF RESORT</b>		DATE <b>7/23/2013</b>	SIGNATURE
LOCATION <b>4949 DESERT KNOLL DR, TWENTYNINE PALMS, CA 92277</b>		REHS <b>Chaz Harrison</b>	

**36K462 Plumbing - Backflow Protection**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no backflow prevention device on hose bib. Ensure a backflow prevention device is installed on hose bib to prevent water backflow into water system.
	Not In Compliance	
	Violation Reference - CCR - 3141B, 3118B	

**Violation Description:** There shall be no direct connection between any potable water supply system and the pool or its piping system unless protected by a backflow prevention device in accordance with Chapter 6 of the California Plumbing Code.  
 There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system.  
 Potable water outlets with hose attachments shall be protected by a nonremovable hose bibb backflow preventer, a nonremovable hose bibb vacuum breaker, or by an atmospheric vacuum breaker.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments