



County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME SHADY TRAILS PARKHOUSE					DATE 7/24/2013	SIGNATURE	
LOCATION 15800 S PARK LN, FONTANA, CA 92336					REINSPECTION DATE 8/07/2013	PERMIT EXPIRATION 3/31/2014	
MAILING ADDRESS 15800 S PARK LN, FONTANA CA 92336					<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Chris Nwadike		
FA # FA0014449	PR # PR0019094	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: spa		
TIME IN 5:22 PM	TIME OUT 5:50 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 13 - Permit Suspended / Facility Closed		

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	102.0
observed flow (gpm)	220
required flow (gpm)	148
volume (gal)	4,435
area (sq ft)	219
occupancy	21

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine level at more than 17.0ppm. Maintain between 1.5 and 10.0ppm. Spa is therefore closed and permit suspended until this correction is made. Call EHS (Chris) at 800-442-2283 for reopening.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments