



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>NORTHSHORE RV RESORT INC</b>					DATE <b>7/25/2013</b>	SIGNATURE	
LOCATION <b>3408 RIVER RD, NEEDLES, CA 92363</b>					REINSPECTION DATE <b>1/25/2014</b>	PERMIT EXPIRATION <b>1/31/2014</b>	
MAILING ADDRESS <b>3408 RIVER RD, NEEDLES, CA 92363</b>					REHS <b>Veronica Vazquez</b>		
FA # <b>FA0005373</b>	PR # <b>PR0015082</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: None		
TIME IN <b>11:16 AM</b>	TIME OUT <b>11:34 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**96**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	0
required flow (gpm)	35
volume (gal)	16,886
area (sq ft)	645
occupancy	32

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed cyanuric acid above 100 ppm.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K460 Skimmers - Requirements**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65533, 3136B

**Inspector Comments:** Observed no suction in pool skimmers. Recommends suction in skimmers is 75% and 25% in main drain.

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**

Ensure the direction of flow for the recirculation equipment is labeled clearly with directional symbols such as arrows on all piping in the equipment area.

These signs will be required by next year:

- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEPCLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

Call Veronica Vazquez with questions at (800) 442-2283.

**Photo Attachments:**

No Photo Attachments