



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

|  |                            |                                |                              |                   |  |                                       |  |
|--|----------------------------|--------------------------------|------------------------------|-------------------|--|---------------------------------------|--|
| FACILITY NAME<br><b>CUCAMONGA RIDGE INC</b>                            |                            |                                |                              |                   | DATE<br><b>7/25/2013</b>                               | SIGNATURE                             |  |
| LOCATION<br><b>8717 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730</b>        |                            |                                |                              |                   | REINSPECTION DATE<br><b>1/25/2014</b>                  | PERMIT EXPIRATION<br><b>5/31/2014</b> |  |
| MAILING ADDRESS<br><b>8717 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730</b> |                            |                                |                              |                   | REHS<br><b>Anies Kondoker</b>                          |                                       |  |
| FA #<br><b>FA0010720</b>   | PR #<br><b>PR0013989</b>   | SR #<br><b>Not Specified</b>   | CO #<br><b>Not Specified</b> | PE<br><b>3601</b> | PROGRAM IDENTIFIER: pool                               |                                       |  |
| TIME IN<br><b>1:10 PM</b>  | TIME OUT<br><b>1:37 PM</b> | CONTACT<br><b>Not Captured</b> |                              |                   | SERVICE: 001 - Inspection - Routine                    |                                       |  |
|  |                            |                                |                              |                   | RESULT: 03 - Corrective Action / No Follow up Required |                                       |  |
|  |                            |                                |                              |                   | ACTION: 01 - No Further Action Required                |                                       |  |




**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

|                   |
|-------------------|
| Ideal             |
| In Compliance     |
| Not in Compliance |



|                     |         |
|---------------------|---------|
| temperature (F)     | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 137     |
| volume (gal)        | 49,000  |
| area (sq ft)        | 1,467   |
| occupancy           | 73      |

**36K448 Equipment - Flow Meter**

|                           |                                   |   |
|---------------------------|-----------------------------------|---|
| <b>POINTS</b><br><b>2</b> | Compliance Date: Not Specified    | <b>Inspector Comments:</b> Repair/replace non-functioning flow meter. |
|                           | Not In Compliance                 |   |
|                           | Violation Reference - CCR - 3125B |   |

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K460 Skimmers - Requirements**

|                           |  |  |
|---------------------------|--|--|
| <b>POINTS</b><br><b>2</b> | Compliance Date: Not Specified           | <b>Inspector Comments:</b> Provide weir gates to all skimmers. |
|                           | Not In Compliance                        |  |
|                           | Violation Reference - CCR - 65533, 3136B |  |

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain**

|                           |   |  |
|---------------------------|---|--|
| <b>POINTS</b><br><b>2</b> | Compliance Date: Not Specified                  | <b>Inspector Comments:</b> Replace broken shower handle. |
|                           | Not In Compliance                               |  |
|                           | Violation Reference - CCR - 65535, 65551, 3117B |  |

**Violation Description:** Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments