



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>LEISURE HOME MHP</b>					DATE <b>7/25/2013</b>	SIGNATURE	
LOCATION <b>600 E RIMROCK RD, BARSTOW, CA 92311</b>					REINSPECTION DATE <b>1/25/2014</b>	PERMIT EXPIRATION <b>8/31/2013</b>	
MAILING ADDRESS <b>PO BOX 91463, LONG BEACH CA 90809-1463</b>					REHS <b>Kathy Taylor</b>		
FA # <b>FA0007054</b>	PR # <b>PR0014011</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool		
TIME IN <b>11:15 AM</b>	TIME OUT <b>11:45 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**96**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	52
volume (gal)	25,000
area (sq ft)	360
occupancy	18

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR - 65529

**Inspector Comments:** Cyanuric acid level slightly higher than highest legal limit of 100 ppm. Lower cyanuric acid by draining a little water out of pool and adding fresh water.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K448 Equipment - Flow Meter**

**POINTS**  
**2**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR - 3125B

**Inspector Comments:** Flowmeter is stuck; dislodge float and ensure minimum flow rate is met. Minimum flowrate for this pool is 52 gallons per minute.

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**Overall Inspection Comments**

pH of pool (acid level) found very low at 7.2. This is the lowest legal limit prior to pool closure. Ensure pH is tested daily and always between 7.2 - 8.0.

Watch chlorine level - low today. Lowest legal limit is 1.5 ppm and testing today at 2.0 ppm. Suggest keeping a chlorine level of about 5.0 ppm. Do not let chlorine level rise above 10 ppm.

Thank you

**Photo Attachments:**

No Photo Attachments