



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|--|--|
| FACILITY NAME SHADY TRAILS PARKHOUSE | | | | DATE 7/25/2013 | SIGNATURE |
| LOCATION 15800 S PARK LN, FONTANA, CA 92336 | | | | REINSPECTION DATE 12/25/2013 | PERMIT EXPIRATION 3/31/2014 |
| MAILING ADDRESS 15800 S PARK LN, FONTANA CA 92336 | | | | REHS Chris Nwadike | |
| <input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT | | | | PROGRAM IDENTIFIER: spa | |
| FA # FA0014449 | PR # PR0019094 | SR # Not Specified | CO # Not Specified | PE 3601 | SERVICE: 003 - Inspection - Follow Up Inspection |
| TIME IN 11:12 AM | TIME OUT 11:56 AM | CONTACT Not Captured | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 15 - Permit Reinstated / Facility Re-opened |

RECREATIONAL HEALTH - PUBLIC POOL/SPA

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 148 |
| volume (gal) | 4,435 |
| area (sq ft) | 219 |
| occupancy | 21 |

36K992 Permit Reinstatement

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: Chlorine level corrected to 5.0ppm.
 The health permit is reinstated and pool/spa is open for use.

Violation Description: The health permit to operate is hereby reinstated and facility may open.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments