



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**




(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>CUCAMONGA RIDGE INC</b>				DATE <b>7/29/2013</b>	SIGNATURE	
LOCATION <b>8717 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730</b>				REINSPECTION DATE <b>12/29/2013</b>	PERMIT EXPIRATION <b>5/31/2014</b>	
MAILING ADDRESS <b>8717 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730</b>				REHS <b>Anies Kondoker</b>		
FA # <b>FA0010720</b>	PR # <b>PR0013990</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: spa	
TIME IN <b>9:23 AM</b>	TIME OUT <b>9:37 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - Inspection - Follow Up Inspection	
					RESULT: 03 - Corrective Action / No Follow up Required	
					ACTION: 15 - Permit Reinstated / Facility Re-opened	

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Ideal
In Compliance
Not in Compliance



temperature (F)	98.0
observed flow (gpm)	No Data
required flow (gpm)	104
volume (gal)	3,108
area (sq ft)	107
occupancy	10

**36K992 Permit Reinstatement**

POINTS  
**NA**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC

Inspector Comments:

Violation Description: The health permit to operate is hereby reinstated and facility may open.

**36K994 Reinspection**

POINTS  
**NA**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC

Inspector Comments:

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

**36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level**

POINTS  
**2**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR - 65529

Inspector Comments: Measured free chlorine at 1 ppm. Maintain at 1.5 - 10 ppm.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments