



County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | | | | | | |
|----------------------------------------------------------------------|-----------------------------|--------------------------------|------------------------------|-------------------|--------------------------------------------------------|----------------------------------------|--|
| FACILITY NAME HERITAGE PARK | | | | | DATE 7/29/2013 | SIGNATURE | |
| LOCATION 9601 LOMITA CT, RANCHO CUCAMONGA, CA 91701 | | | | | REINSPECTION DATE 1/29/2014 | PERMIT EXPIRATION 12/31/2013 | |
| MAILING ADDRESS 9601 LOMITA CT, RANCHO CUCAMONGA, CA 91701 | | | | | REHS Isaac Gebreslassie | | |
| FA # FA0006633 | PR # PR0014804 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: Pool | | |
| TIME IN 11:31 AM | TIME OUT 11:57 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine | | |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required | | |
| | | | | | ACTION: 01 - No Further Action Required | | |




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level in pool water too high. Maintain level of cyanuric acid at below 100 ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Observed flow meter to be not non-functional.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments