



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME QUALITY INN					DATE 7/24/2013	SIGNATURE	
LOCATION 1750 S WATERMAN AV, SAN BERNARDINO, CA 92408					REINSPECTION DATE 8/07/2013	PERMIT EXPIRATION 1/31/2014	
MAILING ADDRESS 1750 S WATERMAN AV, SAN BERNARDINO, CA 92408					REHS Yong Aday		
FA # FA0006654	PR # PR0014802	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool		
TIME IN 9:08 AM	TIME OUT 9:30 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 13 - Permit Suspended / Facility Closed		

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

90

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	26

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: The pool is ordered to be closed due to high chlorine. Call your inspector to reopen when chlorine level is at 1.5-10ppm: Yong Aday at 800-442-2283

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Chlorine level was tested at above 20ppm in the pool.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level at above 100ppm in the pool.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K430 Safety - Equipment/First Aid Kit

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65539

Inspector Comments: Observed deteriorated life ring. Replace as needed.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME QUALITY INN	DATE 7/24/2013	SIGNATURE
LOCATION 1750 S WATERMAN AV, SAN BERNARDINO, CA 92408	REHS Yong Aday	

36K460 Skimmers - Requirements

POINTS	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 65533, 3136B	Inspector Comments: Replace missing float assemblies in the skimmers.
---------------	--	--

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments

Note:

- Post signs at pool area to provide a local emergency service number and facility name/address.
- Pump room was not accessible at this time.

Photo Attachments:

No Photo Attachments