



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>SUNRIDGE PINES APARTMENTS II</b>				DATE <b>7/30/2013</b>	SIGNATURE
LOCATION <b>6592 POST PL, RANCHO CUCAMONGA, CA 91701</b>				REINSPECTION DATE <b>1/30/2014</b>	PERMIT EXPIRATION <b>12/31/2013</b>
MAILING ADDRESS <b>10505 SORRENTO VALLEY RD UNIT 300, SAN DIEGO CA 92121</b>				REHS <b>Isaac Gebreslassie</b>	
FA # <b>FA0005713</b>	PR # <b>PR0014978</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool - east
TIME IN <b>10:45 AM</b>	TIME OUT <b>11:19 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**92**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	50
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	16

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed cyanuric acid level too high. maintain level of cyanuric acid at below 100 ppm.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K446 Equipment - Chlorinator/Heater/Jets**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529, 65535, 3134B...

**Inspector Comments:** Observed chlorinator to be too small for the size of the pool. Provide proportionate size chlorinator.

**Violation Description:** Pools, when open or in use, shall be disinfected continuously by a chemical which imparts a residual effect. Disinfectant feeders shall comply with applicable requirements established by the NSF/ANSI 50-2010 performance standard effective August 2010 for disinfectant feeders. All feeders shall be capable of supplying not less than the equivalent of 3 pounds of 100 percent available chlorine per day per 10,000 gallons of pool water capacity. All parts of the pool and related pool facilities and equipment shall be maintained in good repair. A spa pool aeration and/or jet system shall be completely separate from the recirculation system and shall not be interconnected with any other pool.

**36K460 Skimmers - Requirements**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65533, 3136B

**Inspector Comments:** Observed water level too low. Increase.

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>SUNRIDGE PINES APARTMENTS II</b>	DATE <b>7/30/2013</b>	SIGNATURE
LOCATION <b>6592 POST PL., RANCHO CUCAMONGA, CA 91701</b>	REHS <b>Isaac Gebreslassie</b>	

**36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed inoperable drinking fountain. Repair.
	Not In Compliance	
	Violation Reference - CCR - 65535, 65551, 3117B	

**Violation Description:** Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

**36K429 Safety - Notification - New Sign Requirements**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Ensure facility compliance with the following signs: 1.Contact number for the nearest Fire Department. 2. CPR chart.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments