



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME AMARPAN LLC					DATE 7/31/2013	SIGNATURE	
LOCATION 22526 SIOUX RD, APPLE VALLEY, CA 92308					REINSPECTION DATE 12/31/2013	PERMIT EXPIRATION 5/31/2014	
MAILING ADDRESS 2359 SKYLINE DR, FULLERTON CA 92831					REHS Dawn LaFlower		
FA # FA0005825	PR # PR0014084	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool		
TIME IN 11:28 AM	TIME OUT 11:53 AM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 15 - Permit Reinstated / Facility Re-opened		

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	50
volume (gal)	17,000
area (sq ft)	570
occupancy	28

36K992 Permit Reinstatement

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: Health permit reinstated. Pool approved to open. Observed chlorine measuring 5.0 and pH measuring 7.6 and recirculation system functioning.

Violation Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: Reinspection to determine compliance from routine inspection conducted on 7/25/13. Pool was closed due to low pH levels and recirculation system not functioning during operating hours.

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Health permit reinstated. Pool approved to open.

Photo Attachments:
 No Photo Attachments