



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | | | | | | |
|---|-----------------------------|--------------------------------|------------------------------|-------------------|--|-------------------|--|
| FACILITY NAME ETIWANDA HIGH SCHOOL | | | | | DATE 7/31/2013 | SIGNATURE | |
| LOCATION 13500 VICTORIA ST, RANCHO CUCAMONGA, CA 91739 | | | | | REINSPECTION DATE 1/31/2014 | PERMIT EXPIRATION | |
| MAILING ADDRESS 13500 VICTORIA ST, RANCHO CUCAMONGA, CA 91739 | | | | | REHS Isaac Gebreslassie | | |
| FA # FA0006434 | PR # PR0014041 | SR # Not Specified | CO # Not Specified | PE 3603 | PROGRAM IDENTIFIER: diving pool | | |
| TIME IN 10:52 AM | TIME OUT 11:23 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine | | |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required | | |
| | | | | | ACTION: 01 - No Further Action Required | | |

RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | 680 |
| required flow (gpm) | 66 |
| volume (gal) | 240,000 |
| area (sq ft) | 3,360 |
| occupancy | 168 |

36K474 Lighting - Adequate Lighting and Ventilation

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - SBCC - 3115B, 3106B, 3121B

Inspector Comments: Observed pool light s not fully operating. Repair/replace missing lights.

Violation Description: Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments