



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME LOS OSOS HIGH SCHOOL				DATE 7/31/2013	SIGNATURE
LOCATION 6001 MILLIKEN AV, RANCHO CUCAMONGA, CA 91737				REINSPECTION DATE 1/31/2014	PERMIT EXPIRATION
MAILING ADDRESS 211 W 5TH ST, ONTARIO CA 91762				REHS Isaac Gebreslassie	
FA # FA0011093	PR # PR0016691	SR # Not Specified	CO # Not Specified	PE 3603	PROGRAM IDENTIFIER: pool
TIME IN 11:30 AM	TIME OUT 12:04 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
				RESULT: 03 - Corrective Action / No Follow up Required	ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	142
required flow (gpm)	1,500
volume (gal)	540,000
area (sq ft)	No Data
occupancy	419

36K474 Lighting - Adequate Lighting and Ventilation

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - SBCC - 3115B, 3106B, 3121B

Inspector Comments: Observed a couple of light bulbs not operating. Repair/replace.

Violation Description: Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments