



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | | | | | | |
|--|----------------------------|--------------------------------|------------------------------|-------------------|--|---------------------------------------|--|
| FACILITY NAME LAS BRISAS APARTMENTS | | | | | DATE 8/1/2013 | SIGNATURE | |
| LOCATION 1319 SPRINGFIELD 128, UPLAND, CA 91786 | | | | | REINSPECTION DATE 2/01/2014 | PERMIT EXPIRATION 6/30/2014 | |
| MAILING ADDRESS 4111 SEPULVEDA BL, SHERMAN OAKS CA 91403 | | | | | REHS Shannon Johnson | | |
| FA # FA0008606 | PR # PR0014396 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: EAST SPA | | |
| TIME IN 4:29 PM | TIME OUT 4:59 PM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine | | |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required | | |
| | | | | | ACTION: 01 - No Further Action Required | | |



RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | 101.0 |
| observed flow (gpm) | No Data |
| required flow (gpm) | 43 |
| volume (gal) | 1,276 |
| area (sq ft) | 79 |
| occupancy | 8 |

36K990 Survey Inspection

| | |
|---------------|---|
| POINTS | Compliance Date: Not Specified |
| NA | Not In Compliance |
| | Violation Reference - SBCC - SBC Policy |

Inspector Comments: Correct the following violations.

Violation Description: A survey inspection was conducted on this date.

36K418 Water Quality - Cyanurates

| | |
|---------------|-----------------------------------|
| POINTS | Compliance Date: Not Specified |
| 2 | Not In Compliance |
| | Violation Reference - CCR - 65529 |

Inspector Comments: Observed the cyanuric acid concentration to be greater than 100ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K430 Safety - Equipment/First Aid Kit

| | |
|---------------|-----------------------------------|
| POINTS | Compliance Date: Not Specified |
| 2 | Not In Compliance |
| | Violation Reference - CCR - 65539 |

Inspector Comments: Observed no body hook or life ring at this spa. Provide at least one of these items at this stand alone spa.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

| | |
|---------------|---|
| POINTS | Compliance Date: Not Specified |
| 2 | Not In Compliance |
| | Violation Reference - HSC - 3120B, 3132B, 3141B |

Inspector Comments: Observed no directional symbols on piping within the equipment enclosure.

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | |
|---|--------------------------------|-----------|
| FACILITY NAME LAS BRISAS APARTMENTS | DATE 8/1/2013 | SIGNATURE |
| LOCATION 1319 SPRINGFIELD 128, UPLAND, CA 91786 | REHS Shannon Johnson | |

36K429 Safety - Notification - New Sign Requirements

| | | |
|----------------------------|--------------------------------------|---|
| POINTS NA | Compliance Date: Not Specified | Inspector Comments: Update and correct all safety signs as needed. |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

No access to the equipment enclosure at the time of this inspection. The lack of directional symbols on piping were observed through the door hatch to the enclosure.

Photo Attachments:

No Photo Attachments