



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>CHAMBRAY APARTMENTS</b>					DATE <b>7/29/2013</b>	SIGNATURE	
LOCATION <b>7828 DAY CREEK BL, RANCHO CUCAMONGA, CA 91739</b>					REINSPECTION DATE <b>8/12/2013</b>	PERMIT EXPIRATION <b>11/30/2013</b>	
MAILING ADDRESS <b>7828 DAY CREEK BL, RANCHO CUCAMONGA CA 91739</b>					REHS <b>Grace Cat</b>		
FA # <b>FA0014237</b>	PR # <b>PR0018807</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool		
TIME IN <b>10:41 AM</b>	TIME OUT <b>11:18 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 13 - Permit Suspended / Facility Closed		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**82**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	113
volume (gal)	40,680
area (sq ft)	1,365
occupancy	94

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:** The facility's health permit is suspended due the unsafe chlorine level. Contact the Environmental Health Services Office at 800-442-2283 when ready to be reopened.

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K404 Water Quality - Critical - High Disinfectant Level**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Measured the chlorine inside the pool higher than 10 ppm. Maintain free chlorine level between 1.5 - 10 ppm at all times.

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K438 Enclosure - Critical - Gates Drowning Hazard**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC - 3119B

**Inspector Comments:** Observed the west entrance gate leading into the pool/spa area not self-closing/self-latching. Ensure all doors and gates leading into the pool/spa areas are secured and always self-closing/self-latching. Corrected on site, operator immediately fixed gate at the end of inspection.

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

**36K418 Water Quality - Cyanurates**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Measured cyanuric acid level above 100 ppm. Maintain cyanuric acid level below 100 ppm at all times.

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>CHAMBRAY APARTMENTS</b>		DATE <b>7/29/2013</b>	SIGNATURE
LOCATION <b>7828 DAY CREEK BL, RANCHO CUCAMONGA, CA 91739</b>		REHS <b>Grace Cat</b>	

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed the direction of flow for the recirculation equipment not labeled clearly with directional symbols such as arrows on all piping in the equipment area. Provide labels.
	Violation Reference - HSC - 3120B, 3132B, 3141B	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed flow meter not readable. Repair/replace the non-functional flow meter; and ensure to maintain a minimum flow rate of 113 gpm at all times.
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K460 Skimmers - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Provide the missing weir gate inside the skimmer near the office.
	Violation Reference - CCR - 65533, 3136B	

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**36K472 Access - Steps - Handrails - Diving Area**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed main handrail not stable. Repair/replace.
	Violation Reference - CCR - 3111B, 3113B	

**Violation Description:** Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>CHAMBRAY APARTMENTS</b>	DATE <b>7/29/2013</b>	SIGNATURE
LOCATION <b>7828 DAY CREEK BL, RANCHO CUCAMONGA, CA 91739</b>	REHS <b>Grace Cat</b>	

**36K429 Safety - Notification - New Sign Requirements**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Ensure to provide all the new, up-to-date sign requirements by the next pool season: May 2014.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** Effective September 2012, sign requirements changed. This is not a violation at this time but shall be corrected prior to the 2014 pool season. Failure to comply may result in a violation. The new sign requirements are as follows:

All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments