



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME COUNTRY VIEW TOWNHOUSES				DATE 8/5/2013	SIGNATURE
LOCATION 4150 SCHAEFFER, CHINO, CA 91710				REINSPECTION DATE 8/19/2013	PERMIT EXPIRATION 7/31/2013
MAILING ADDRESS 4150 SCHAEFFER, CHINO, CA 91710				REHS Nick Thalasin	
FA # FA0008495	PR # PR0013812	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa
TIME IN 11:00 AM	TIME OUT 11:35 AM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension **⚠ CRITICAL ⚠**

POINTS NA	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K438 Enclosure - Critical - Gates Drowning Hazard **⚠ CRITICAL ⚠**

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed that the Landscapers prop the pool gate open then leave it unattended; This is an extremely dangerous practice, Cease and Desist.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

36K442 Equipment - Critical - Non-Functioning Recirculation System **⚠ CRITICAL ⚠**

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed that the Spa Pump and Filtration system is not Operational; The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use.
	Not In Compliance	
	Violation Reference - CCR - 65525	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use.

Overall Inspection Comments

The Permit to operate is SUSPENDED and the Spa is CLOSED.

Photo Attachments:
No Photo Attachments