



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME ORCHARD LANE CONDO				DATE 8/6/2013	SIGNATURE
LOCATION 1380 MAXWELL , UPLAND, CA 91786				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2014
MAILING ADDRESS 1693 W 9TH ST, UPLAND CA 91786				REHS Leilah Kelsey	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: North Spa	
FA # FA0008542	PR # PR0015375	SR # Not Specified	CO # Not Specified	PE 3601	SERVICE: 153 - Response to Pool Survey
TIME IN 10:00 AM	TIME OUT 10:05 AM	CONTACT Not Captured			RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K951 Surveyor Referral

POINTS NA	Compliance Date: Not Specified	Inspector Comments: During a safety survey, the pool aide from Environmental Health Services (EHS) found the clarity in the spa to be poor. They were unable to clearly see the bottom of the spa. The spa was posted closed, not to be used, for this safety hazard. Please call your inspector at 800-442-2283 for an inspection prior to reopening your spa. Do not reopen your spa for service without approval from EHS.
	Not In Compliance	
	Violation Reference - SBC - SBC Policy	

Violation Description: A referral from an Environmental Health Pool Surveyor has resulted in the closure of your pool/spa. Immediately correct the noted violations. The pool/spa is to remain closed until EHS has given permission to reopen the facility.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments