



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT




(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME LIFESTYLE APARTMENTS				DATE 8/7/2013	SIGNATURE
LOCATION 16324 MERRILL AV, FONTANA, CA 92335				REINSPECTION DATE 8/21/2013	PERMIT EXPIRATION 9/30/2013
MAILING ADDRESS 8150 COTTONWOOD AV, FONTANA CA 92335				REHS Chris Nwadike	
FA # FA0006522	PR # PR0013588	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: spa
TIME IN 11:04 AM	TIME OUT 11:32 AM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	25
volume (gal)	735
area (sq ft)	28
occupancy	2

36K992 Permit Reinstatement

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: Observed chlorine level at more than 17.0ppm.
 Maintain between 1.5 and 10.0ppm.
 Observed the pH at 7.0
 Maintain between 7.2 and 8.0.
 The spa remains closed and the permit still suspended until all the corrections are made.
 Call EHS (Chris) at 1800-442-2283 for spa reopening. A fee of \$245.00 per hour will apply.

Violation Description: The health permit to operate is hereby reinstated and facility may open.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments