



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>GOLD WEST MOBILEHOME PARK</b>				DATE <b>8/8/2013</b>	SIGNATURE <i>see phase 3 pool</i>
LOCATION <b>15252 SENECA RD, VICTORVILLE, CA 92392</b>				REINSPECTION DATE <b>2/08/2014</b>	PERMIT EXPIRATION <b>6/30/2014</b>
MAILING ADDRESS <b>15252 SENECA RD, VICTORVILLE CA 92392</b>				REHS <b>Veronica Vazquez</b>	
FA # <b>FA0008791</b>	PR # <b>PR0014246</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: <b>West phase II pool</b>
TIME IN <b>11:00 AM</b>	TIME OUT <b>11:19 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>001 - Inspection - Routine</b>
					RESULT: <b>01 - Corrective Action Not Required</b>
					ACTION: <b>01 - No Further Action Required</b>

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**100**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	80
required flow (gpm)	70
volume (gal)	25,500
area (sq ft)	800
occupancy	40

**No Violations Cited**

**Overall Inspection Comments**

These signs will be required by next year:

- a) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- b) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- c) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- d) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

Call Veronica Vazquez with questions at (800) 442-2283.

**Photo Attachments:**

No Photo Attachments