



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME EMERALD COVE RESORT				DATE 8/9/2013	SIGNATURE <i>see old pool report</i>
LOCATION 2715 PARKER DAM RD, EARP, CA 92242				REINSPECTION DATE 2/09/2014	PERMIT EXPIRATION 6/30/2014
MAILING ADDRESS PO BOX 1128, PARKER AZ 85344				REHS Veronica Vazquez	
FA # FA0006118	PR # PR0014896	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa (Old)
TIME IN 11:45 AM	TIME OUT 11:59 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	103.0
observed flow (gpm)	70
required flow (gpm)	46
volume (gal)	1,380
area (sq ft)	64
occupancy	6

36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level

POINTS
2

Comply by: 8/10/2013
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Ensure free chlorine residual is maintained at 1.5 ppm when using cyanuric acid. Observed free chlorine residual at 1.0.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

36K414 Water Quality - Non-Critical - pH High/Low

POINTS
2

Comply by: 8/10/2013
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Ensure pH is between 7.2 and 8.0. Observed pH at 7.0 in old spa.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Ensure flow meter is 10% accurate to 46 gpm. Observed flow meter reading 70 gpm.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K466 Structure - Pool Shell

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3108B

Inspector Comments: Ensure spa shell is in good repair. Observed bottom of shell peeling of paint and spa stairs cracking.

Recommend replastering old spa.

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME EMERALD COVE RESORT	DATE 8/9/2013	SIGNATURE <i>see old pool report</i>
LOCATION 2715 PARKER DAM RD, EARP, CA 92242	REHS Veronica Vazquez	

These signs will be required by next year:

- a) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- b) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- c) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- d) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

Call Veronica Vazquez with questions at (800) 442-2283.

Photo Attachments:

No Photo Attachments