



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME AYALA HIGH SCHOOL					DATE 8/12/2013	SIGNATURE	
LOCATION 14255 PEYTON DR, CHINO HILLS, CA 91709					REINSPECTION DATE 8/26/2013	PERMIT EXPIRATION	
MAILING ADDRESS 14255 PEYTON DR, CHINO HILLS, CA 91709					REHS Tin Nguyen		
FA # FA0003095	PR # PR0015489	SR # Not Specified	CO # Not Specified	PE 3603	PROGRAM IDENTIFIER: Pool		
TIME IN 10:08 AM	TIME OUT 11:50 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 13 - Permit Suspended / Facility Closed		




RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments:

-Pool permit is suspended due to gates not self-latching and self-closing.
-Pool is ordered closed by Division of Environmental Health Services (DEHS) due to gates not self-latching and self-closing. DO NOT OPEN POOL UNTIL AUTHORIZED BY DEHS. Non-compliance will result in future charged re-inspections at \$245.00 per hour.

-Contact DEHS at 1(800) 442-2283 when ready to re-open.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K438 Enclosure - Critical - Gates Drowning Hazard

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 3119B

Inspector Comments: Observed gates not self-latching and self-closing. There are three gates around pool area. Ensure all gates are properly self-latching and self-closing.

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

36K456 Maintenance - Spa/Pool Area - Pump Room

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65535

Inspector Comments: -Observed brown rust on pool shell (near 4 feet at restrooms). Repair/replace.

Violation Description: All parts of the pool and related pool facilities and equipment shall be maintained in good repair. Floors shall be kept free from cracks and other defects. Walls, ceilings, partitions, doors and similar surfaces and equipment shall be refinished in a manner acceptable to DEHS as often as necessary to be kept in a state of good repair. Hoses shall be provided for regular flushing and cleaning. The whole pool area shall be kept clean, sanitary and free of litter and vermin.

Overall Inspection Comments

pH: 7.4
Chlorine: 1.5 ppm
CYA: 0 ppm
Flow rate: n/a



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME AYALA HIGH SCHOOL	DATE 8/12/2013	SIGNATURE
LOCATION 14255 PEYTON DR, CHINO HILLS, CA 91709		REHS Tin Nguyen

Photo Attachments:

No Photo Attachments