



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**


(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>LIFESTYLE APARTMENTS</b>				DATE <b>8/13/2013</b>	SIGNATURE <i>Rosa E Rando</i>
LOCATION <b>16324 MERRILL AV, FONTANA, CA 92335</b>				REINSPECTION DATE <b>1/13/2014</b>	PERMIT EXPIRATION <b>9/30/2013</b>
MAILING ADDRESS <b>8150 COTTONWOOD AV, FONTANA CA 92335</b>				REHS <b>Chris Nwadike</b>	
FA # <b>FA0006522</b>	PR # <b>PR0013588</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: spa
TIME IN <b>2:01 PM</b>	TIME OUT <b>2:50 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 037 - Pool/Spa - Billable Inspection Services
					RESULT: 01 - Corrective Action Not Required
					ACTION: 15 - Permit Reinstated / Facility Re-opened

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	25
volume (gal)	735
area (sq ft)	28
occupancy	2

**36K992 Permit Reinstatement**

<b>POINTS</b>  <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Chlorine level corrected to 3.5ppm. pH corrected to 7.8 The health permit is reinstated and spa is open for use.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** The health permit to operate is hereby reinstated and facility may open.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments