



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>SUNCREST APARTMENTS</b>					DATE <b>8/15/2013</b>	SIGNATURE	
LOCATION <b>201 N YUCCA ST, BARSTOW, CA 92311</b>					REINSPECTION DATE <b>2/15/2014</b>	PERMIT EXPIRATION <b>1/31/2014</b>	
MAILING ADDRESS <b>201 N YUCCA ST, BARSTOW, CA 92311</b>					REHS <b>Kathy Taylor</b>		
FA # <b>FA0012828</b>	PR # <b>PR0016815</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Spa SERVICE: 001 - Inspection - Routine		
TIME IN <b>2:30 PM</b>	TIME OUT <b>2:50 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 03 - Corrective Action / No Follow up Required ACTION: 01 - No Further Action Required		


**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**90**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	39
volume (gal)	1,141
area (sq ft)	77
occupancy	7

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Add chlorine to spa; found at 0.5 ppm today and spa will get cloudy quickly if no chlorine is added. Provide a chlorine level at least 1.5 ppm but not more than 10 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K426 Safety - Emergency Shut-Off Switch**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Replace missing "Emergency Cutoff Switch" at spa jet switch. Unlabeled today.
	Not In Compliance	
	Violation Reference - CCR - 3138B	

**Violation Description:** A clearly labeled emergency shut off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Flowmeter is stuck; dislodge float and ensure the minimum flow for this spa is met.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K454 Maintenance - Cleanliness**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Spa showing signs of an algae problem; begin a regime NOW to remove black algae. Colonies found near steps. The low chlorine level is also allowing the algae to grow. Contact your pool service to begin immediate removal.
	Not In Compliance	
	Violation Reference - CCR - 65533	

**Violation Description:** Floating scum, sputum or debris shall not be allowed to accumulate in the pool. The bottom and sides of the pool shall be cleaned as often as necessary to be kept in a clean condition. The sides and bottom of pools, decks and other surfaces shall be kept free of slime and algae.

**Overall Inspection Comments**



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>SUNCREST APARTMENTS</b>	DATE <b>8/15/2013</b>	SIGNATURE
LOCATION <b>201 N YUCCA ST, BARSTOW, CA 92311</b>		REHS <b>Kathy Taylor</b>

Improve spa water clarity - water is not very clear.

Contact this department for new spa sign requirements that go into effect next year. Please call 1-800-442-2283 if you have questions.

Thank you

**Photo Attachments:**

No Photo Attachments