



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME COUNTRY CLUB VILLAS				DATE 8/22/2013	SIGNATURE
LOCATION 15447 POMONA RINCON RD, CHINO HILLS, CA 91709				REINSPECTION DATE 1/22/2014	PERMIT EXPIRATION 9/30/2013
MAILING ADDRESS 842 W ROBINDALE ST, WEST COVINA CA 91790-4926				REHS Tin Nguyen	
FA # FA0015983	PR # PR0021252	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 9:36 AM	TIME OUT 9:46 AM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	49
volume (gal)	17,786
area (sq ft)	558
occupancy	28

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: -Pool permit is reinstated. -Gate to pool/spa is properly self-closing and self-latching. -Chlorine level in pool measured at 6.5 ppm.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: -A re-inspection was conducted a facility regarding gate (near pool) and chlorine level in pool. -Upon re-inspection, observed gate self-closing and self-latching and chlorine level at 6.5 ppm in pool.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Chlorine: 6.5 ppm

Photo Attachments:
No Photo Attachments