



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME URENO APARTMENTS					DATE 8/22/2013	SIGNATURE	
LOCATION 1340 YUCCA DR, SAN BERNARDINO, CA 92404					REINSPECTION DATE 2/22/2014	PERMIT EXPIRATION 6/30/2014	
MAILING ADDRESS PO BOX 1763, ANAHEIM CA 92815-1763					REHS Chaz Harrison		
FA # FA0005178	PR # PR0014106	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool		
TIME IN 2:50 PM	TIME OUT 3:31 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid level above 100 ppm. Cyanuric acid shall not exceed 100 ppm. Cyanuric acid can be lowered by slightly draining the pool/spa and adding fresh water.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K430 Safety - Equipment/First Aid Kit

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65539

Inspector Comments: Observed no rope attached to life ring. All swimming pools are required to provide a life ring with an outside diameter of 17 inches and a rope (at least 3/16 inches in diameter) attached that is long enough to span the widest part of the pool.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Observed non functioning flow meter. Repair/replace.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K458 Maintenance - Test Kit/Daily Records

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65523, 65529

Inspector Comments: Observed no test kit. Ensure to obtain a DPD test kit. Taylor k-2009(recommended). Observed no daily pool records on site. Ensure to maintain daily records for pool. Pool Code sec. 65523 states: "The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used." Also it states: "If cyanuric acid is used..., the cyanuric acid concentration shall be measured a minimum of once per month and records shall be kept of the results of such testing."
If the pool service person is only at the site 3 days a week, there needs to be someone else to record the chlorine and pH on the other 4 days. The only way poor chemistry can be corrected is if someone knows that it is "poor."

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME URENO APARTMENTS	DATE 8/22/2013	SIGNATURE
LOCATION 1340 YUCCA DR, SAN BERNARDINO, CA 92404		REHS Chaz Harrison

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments