



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>ECONO LODGE</b>					DATE <b>8/26/2013</b>	SIGNATURE	
LOCATION <b>1230 E MAIN ST, BARSTOW, CA 92311</b>					REINSPECTION DATE <b>2/26/2014</b>	PERMIT EXPIRATION <b>6/30/2014</b>	
MAILING ADDRESS <b>10705 MAGNOLIA AV, RIVERSIDE CA 92505</b>					REHS <b>Kathy Taylor</b>		
FA # <b>FA0008634</b>	PR # <b>PR0013892</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool		
TIME IN <b>9:05 AM</b>	TIME OUT <b>9:40 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	60
volume (gal)	30,000
area (sq ft)	800
occupancy	40

**36K430 Safety - Equipment/First Aid Kit**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65539

**Inspector Comments:** Provide life ring in pool area. None in pool area.

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

**36K448 Equipment - Flow Meter**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3125B

**Inspector Comments:** Repair stuck flowmeter; flowmeter should read about 60 gallons per minute.

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K466 Structure - Pool Shell**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3108B

**Inspector Comments:** Pool shell is blue; over winter season, replaster pool WHITE only.

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

**Overall Inspection Comments**



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>ECONO LODGE</b>	DATE <b>8/26/2013</b>	SIGNATURE
LOCATION <b>1230 E MAIN ST, BARSTOW, CA 92311</b>		REHS <b>Kathy Taylor</b>

Suggest raising pool chlorine slightly - found at lowest legal limit today.

Remember: pool shell needs to be replastered (not repainted) prior to next pool season.

Next pool season new sign requirements will go into effect. Contact this department if you have questions at 1-800-442-2283.

Thank you

NOTE: Contact DEHS Plan check for continental breakfast; in the meantime, discontinue serving milk, juice, etc. and offer only prepackaged and prelabeled pastries and coffee only.

**Photo Attachments:**

No Photo Attachments