



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME PACIFIC PALMS MOBILEHOME PARK					DATE 8/28/2013	SIGNATURE <i>Dana Henderson</i>	
LOCATION 2727 E PACIFIC ST, SAN BERNARDINO, CA 92410					REINSPECTION DATE 2/28/2014	PERMIT EXPIRATION 12/31/2013	
MAILING ADDRESS PO BOX 11927, SANTA ANA CA 92711					REHS Cecilia Jones		
FA # FA0008848	PR # PR0015680	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Office Spa		
TIME IN 2:13 PM	TIME OUT 2:37 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	30
required flow (gpm)	28
volume (gal)	840
area (sq ft)	56
occupancy	5

36K414 Water Quality - Non-Critical - pH High/Low

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Observed pH exceeding 8.0 ppm. Maintain between 7.2 and 8.0.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid exceeding 100 ppm. Maintain below 100 ppm. Ideal concentration is 30 ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments