



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT


(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME HIGHLAND VLG TOWNHOMES				DATE 8/27/2013	SIGNATURE
LOCATION 166 W WALNUT , RIALTO, CA 92376				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 9/30/2013
MAILING ADDRESS PO BOX 1510, UPLAND CA 91785-1510				REHS Leilah Kelsey	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: Spa	
FA # FA0005475	PR # PR0015066	SR # Not Specified	CO # Not Specified	PE 3601	SERVICE: 153 - Response to Pool Survey
TIME IN 2:30 PM	TIME OUT 2:35 PM	CONTACT Not Captured			RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	5

36K951 Surveyor Referral

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - SBCC - SBC Policy

Inspector Comments: During a safety survey, the pool aide from Environmental Health Services (EHS) found the light in the pool to be detached from the wall. The pool was posted closed, not to be used, for this safety hazard. Please call your inspector at 800-442-2283 for an inspection prior to reopening your pool. Do not reopen your pool for service without approval from EHS.

Violation Description: A referral from an Environmental Health Pool Surveyor has resulted in the closure of your pool/spa. Immediately correct the noted violations. The pool/spa is to remain closed until EHS has given permission to reopen the facility.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments