



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME ARROWHEAD VILLAS				DATE 8/30/2013	SIGNATURE
LOCATION 3700 MOUNTAIN AV, SAN BERNARDINO, CA 92404				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2013
MAILING ADDRESS 3756 TIBBETTS ST, RIVERSIDE CA 92506				REHS Chaz Harrison	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: pool	
FA # FA0008863	PR # PR0015759	SR # Not Specified	CO # Not Specified	PE 3601	SERVICE: 008 - Inspection - Attempted
TIME IN 3:51 PM	TIME OUT 4:23 PM	CONTACT Not Captured			RESULT: 00 - Not Applicable
					ACTION: 00 - Not Applicable

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K996 Attempted Inspection

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments:

Violation Description: An inspection was attempted today. Another inspection will be attempted at a later date.

36K426 Safety - Emergency Shut-Off Switch

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 3138B

Inspector Comments: Emergency shut off observed not functioning. Ensure emergency shut off is repaired before reopening the spa. Ensure emergency shut off turns off jets and pump.

Violation Description: A clearly labeled emergency shut off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments