



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT


(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME LINCOLN ELEMENTARY SCHOOL				DATE 10/22/2013	SIGNATURE
LOCATION 440 N ALLYN ST, ONTARIO, CA 91764				REINSPECTION DATE 3/22/2014	PERMIT EXPIRATION
MAILING ADDRESS 950 W D ST, ONTARIO CA 91762				REHS Sierra Clayborn	
FA # FA0002540	PR # PR0016970	SR # Not Specified	CO # Not Specified	PE 3603	PROGRAM IDENTIFIER: Pool
TIME IN 4:57 PM	TIME OUT 5:02 PM	CONTACT Not Captured			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: It has been determined that the recirculation system, pool and spa do not need to be separated at this time. In the event of any major remodeling, the pool and spa as well as the recirculation system for each body of water will need to be separated to meet pool code requirements.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments