



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>MCDONALD'S</b>				DATE <b>11/1/2013</b>	SIGNATURE	
LOCATION <b>4310 MILLS CR, ONTARIO, CA 91764</b>				REINSPECTION DATE <b>11/08/2013</b>	PERMIT EXPIRATION <b>5/31/2014</b>	
MAILING ADDRESS <b>3155 E. SEDONA CT UNIT A, ONTARIO CA 91764</b>				<input type="checkbox"/> FACILITY <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT REHS <b>Anies Kondoker</b>		
FA # <b>FA0000569</b>	PR # <b>PR0012417</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>1621</b>	PROGRAM IDENTIFIER: None	
TIME IN <b>1:45 PM</b>	TIME OUT <b>2:08 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
				RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIR		
				ACTION: 03 - REINSPECTION REQUIRED		

**RETAIL FOOD PROTECTION - PUBLIC EATING PL (25-99 SEATS)**

**16K994 Reinspection**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:**

**Violation Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

- The inspector run the water in women restroom for more than 5 minutes but hot water at min. 100 F was not available.
- Observed hot water at kitchen hand sink reach 100 F after the hot water faucet was opened for more than 3 minutes.
- Measured water at 120 F at 3-compartment sink.

Ensure that water at min. 100 F is available at all hand sinks in timely manner. The employees shall not wait for a long time for the warm water (at least 100 F) to flow.

Please correct this violation by 11/8/13 to avoid another charged inspection or office hearing.

**Photo Attachments:**

No Photo Attachments