



COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME KINGSWOOD FUSIIION POTS					DATE 11/14/2013	SIGNATURE	
LOCATION 13788 ROSWELL AV 188, CHINO, CA 91710					REINSPECTION DATE 4/14/2014	PERMIT EXPIRATION 2/28/2014	
MAILING ADDRESS 15965 BEGONIA AV , CHINO CA 91708					<input type="checkbox"/> FACILITY <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT REHS Nick Thalasinos		
FA # FA0016039	PR # PR0021329	SR # Not Specified	CO # Not Specified	PE 1621	PROGRAM IDENTIFIER: Retail-Food		
TIME IN 1:40 PM	TIME OUT 2:06 PM	CONTACT Not Captured			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION		
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

RETAIL FOOD PROTECTION - PUBLIC EATING PL (25-99 SEATS)

16K994 Reinspection

Compliance Date: Not Specified

Inspector Comments:

Not In Compliance

Violation Reference - HSC

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

I rechecked the separate ventilation units over the dinning room tables; The Manager reports they had the mechanical ventilation hoods checked. I checked the units - they are working, but the flow does not seem as strong as it should be. I advised the facility to close the return air vents facing the units. Close out.

Photo Attachments:

No Photo Attachments