



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME MCDONALD'S				DATE 1/13/2014	SIGNATURE <i>Cecilio Sanchez</i>
LOCATION 1615 S RIVERSIDE AV, RIALTO, CA 92376				REINSPECTION DATE 6/13/2014	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS 15259 GLEN RIDGE DR, CHINO HILLS CA 91709				REHS Amanda Gaspard	
FA # FA0011187	PR # PR0002646	SR # Not Specified	CO # Not Specified	PE 1621	PROGRAM IDENTIFIER: None
TIME IN 2:15 PM	TIME OUT 2:38 PM	CONTACT Not Captured			SERVICE: 013 - FOOD - BILLABLE INSPECTION SERVICES
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RETAIL FOOD PROTECTION - PUBLIC EATING PL (25-99 SEATS)

16K993 Re-Reinspection

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: During routine inspection on 1-3-14, observed water temperature violations. At the beginning of the inspection, observed water at handwashing sink (in kitchen area) at 85F. Observed water at prep sink at 89F (prep sink is directly adjacent to handwashing sink). Observed water at handwashing sink in front service area at 82F. Ran water for several minutes at each of these three sinks, but could not obtain warm water. (Observed water at 3-compartment sink at 122F.) Operator telephoned maintenance personnel, who informed her that the water might take up to 30 minutes to heat up in the water tank. Approximately 1 hr. and 15 minutes later, temp'ed water in women's restroom at 79F. Approximately 1 hr. 45 minutes into the inspection, observed water in men's restroom at 103F. Approximately 3 hours into inspection, temp'ed water at back handwashing sink at 108F. Water at handwashing sink in front service area was temp'ed at 84F.

Facility was given 48 hours to correct the water temperature violations. Facility was told to take the necessary steps to ensure that water is provided at 100F or above at all handwashing sinks and prep sinks in the facility.

During re-inspection on 1-7-14, observed the following:

- 1) Water at the handwashing sink (in the kitchen area) at 95F.
- 2) Water at the prep sink at 93F.
- 3) Water at the handwashing sink (in the front service area) at 75F.
- 4) Water at the handwashing sink in the women's restroom at 138F.
- 5) Water at the handwashing sink in the men's restroom at 135F.

Facility did not yet reach compliance with water temperature requirements. Facility was given 48 hours to correct the water temperature violations. Facility was told to take the necessary steps to ensure that water is provided at 100F or above at all handwashing sinks and prep sinks in the facility.

During the billable re-re-inspection on 1-13-14, observed the following:

- 1) Water at the handwashing sink (in the kitchen area) at 111F.
- 2) Water at the prep sink at 121F.
- 3) Water at the handwashing sink (in the front service area) at 111F.
- 4) Water at the handwashing sink in the women's restroom at 122F.
- 5) Water at the handwashing sink in the men's restroom at 117F.
- 6) Water at the 3-compartment sink at 125F.

Facility is now in compliance with water temperature requirements. No further action in this area is required.

Violation Description: Billable re-reinspection conducted at this time to determine compliance from prior reinspection.

Overall Inspection Comments

Facility is now in compliance with water temperature requirements. No further action in this area is required.

Photo Attachments:

No Photo Attachments