



County of San Bernardino • Department of Public Health
Division of Environmental Health Services

COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

(800) 442-2283

www.sbcounty.gov/dph/dehs

| | | | | | |
|---|----------------------------|--------------------------------|------------------------------|---|--|
| FACILITY NAME M & M I-10 TRUCK STOP COR | | | | DATE 1/24/2014 | SIGNATURE |
| LOCATION 195 E VALLEY BL, RIALTO, CA 92376 | | | | REINSPECTION DATE 6/24/2014 | PERMIT EXPIRATION 5/31/2014 |
| MAILING ADDRESS 195 E VALLEY BL, RIALTO, CA 92376 | | | | <input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT REHS Amanda Gaspard | |
| FA # FA0001246 | PR # PR0003729 | SR # Not Specified | CO # Not Specified | PE 1646 | PROGRAM IDENTIFIER: None |
| TIME IN 9:17 AM | TIME OUT 9:31 AM | CONTACT Not Captured | | | SERVICE: 013 - FOOD - BILLABLE INSPECTION SERVICES |
| | | | | | RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED |
| | | | | | ACTION: 01 - NO FURTHER ACTION REQUIRED |

RETAIL FOOD PROTECTION - CONVENIENCE STORE (0-499 SQFT)

16K993 Re-Reinspection

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: During routine inspection on 1-7-14, observed that the cold water faucet at the 3-compartment sink was broken. Observed that the hot water faucet at the 3-compartment sink could only provide cold water (highest temperature was measured at 68F). (Note: hottest water in facility was temp'ed at 102F at the handwashing sink.) Operator stated that the hot water heating unit for the 3-compartment sink was broken and they are in the process of repairing it. Operator stated that 3-compartment sink is used for cleaning soda dispenser nozzles, coffee pots, and parts to coffee machine.

Facility was told to take the following actions immediately:

- 1) Repair cold water faucet of 3-compartment sink.
- 2) Repair hot water heating unit for 3-compartment sink, so that water can be provided at 100F and above.
- 3) Ensure that at least one sink in the facility can provide hot water at 120F and above (note: facility only has handwashing sink and 3-compartment sink, so one of these two sinks must provide water at 120F and above).

Facility was given 48 hours to comply with the above-mentioned requirements.

During re-inspection on 1-13-14, observed the following:

- 1) Cold water faucet at 3-compartment sink had been repaired.
- 2) Hottest water in facility was temp'ed at 109F at the handwashing sink.
- 3) Highest temperature at 3-compartment sink was measured at 67F.

Operator stated that he had phoned maintenance repair person, but he has not come to facility yet. Facility did not yet meet compliance with hot water requirements.

Facility was told to take the following steps immediately:

- 1) Repair hot water heating unit for 3-compartment sink, so that water can be provided at 100F and above.
- 2) Ensure that at least one sink in the facility can provide hot water at 120F and above (note: facility only has handwashing sink and 3-compartment sink, so one of these two sinks must provide water at 120F and above).

Facility was given 48 hours to comply with the above-mentioned requirements.

During the billable re-re-inspection on 1-24-14, observed the following:

- 1) Observed water at 122F at hot water portion of faucet at the 3-compartment sink (cold water portion of faucet was also functional).
- 2) Observed that hot water heating unit for 3-compartment sink had been repaired.
- 3) Observed water at handwashing sink at 107F.

Facility is now in compliance with hot water requirements. No further action in this area is required.

Violation Description: Billable re-reinspection conducted at this time to determine compliance from prior reinspection.

Overall Inspection Comments

No further action in this area is required.

Photo Attachments:

No Photo Attachments