



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME RODEO BAR				DATE 2/19/2014	SIGNATURE <i>Amanda Gaspard</i>
LOCATION 18666 VALLEY BL, BLOOMINGTON, CA 92316				REINSPECTION DATE 7/19/2014	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS 18666 VALLEY BL, BLOOMINGTON CA 92316-1838				REHS Amanda Gaspard	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: None	
FA # FA0007836	PR # PR0000019	SR # Not Specified	CO # Not Specified	PE 1621	SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
TIME IN 5:19 PM	TIME OUT 5:33 PM	CONTACT Not Captured			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RETAIL FOOD PROTECTION - PUBLIC EATING PL (25-99 SEATS)

16K994 Reinspection

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: During routine inspection on 2-18-14, observed that there was no hot or warm water in facility. Temp'ed water at handwashing sink in men's restroom at 72F. Temp'ed water at handwashing sink in women's restroom at 72F. Temp'ed water at 3-compartment sink at 71F.

Maintenance repair person came during inspection; hot water heater flame (pilot light) had gone out, so he re-lit it. At end of inspection temp'ed water at handwashing sink in women's restroom at 89F.

Facility was given 24 hours to comply with the following water temperature requirements:

- 1) At least one sink in the facility can provide water at 120F or higher.
- 2) Water can be provided at all handwashing sinks at 100F or above.
- #) Water can be provided at the warewashing sink at 100F or above.

During re-inspection on 2-19-14, observed the following:

- 1) Water at 146F at handwashing sink in women's restroom.
- 2) Water at 142F at handwashing sink in men's restroom.
- 3) Water at 141F at 3-compartment warewashing sink.

Facility is now in compliance with water temperature requirements. No further action in this area is required.

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Facility is now in compliance with water temperature requirements. No further action in this area is required.

Photo Attachments:

No Photo Attachments