



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>RADISSON ONTARIO AIRPORT</b>					DATE <b>4/3/2014</b>	SIGNATURE	
LOCATION <b>2200 E HOLT BL, ONTARIO, CA 91761</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>8/31/2014</b>	
MAILING ADDRESS <b>2155 E CONVENTION CENTER WY, ONTARIO CA 91764</b>					REHS <b>Chaz Harrison</b>		
FA # <b>FA0006518</b>	PR # <b>PR0013910</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3605</b>	PROGRAM IDENTIFIER: Spa		
TIME IN <b>4:24 PM</b>	TIME OUT <b>4:51 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - PUBLIC SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**92**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).  Corrected on site.  Corrected to 6ppm
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pH level above 8.0. Ensure to bring pH level between 7.2-8.0. Use Muriatic Acid to decrease the Total Alkalinity of pool.  Corrected on Site.  Corrected to 7.4
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments