



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME SYCAMORE PARK APARTMENTS					DATE 4/8/2014	SIGNATURE	
LOCATION 1221 N VINEYARD , ONTARIO, CA 91764					REINSPECTION DATE Not Specified	PERMIT EXPIRATION	
MAILING ADDRESS 1151 N DEL RIO PL ONTARIO, CA 91764					REHS Bennetta Betbadal		
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT					PROGRAM IDENTIFIER: None		
FA # FA0008579	PR # Not Specified	SR # SR0063072	CO # Not Specified	PE 3755	SERVICE: 025 - PLAN REVIEW		
TIME IN 1:45 PM	TIME OUT 2:00 PM	CONTACT Not Captured			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
					ACTION: 55 - PLANS APPROVED		

RECREATIONAL HEALTH PLAN CHECK - PLAN CHECK REC HEALTH CONSULTATIO

37K980 Plans - Plan Review Approved

Compliance Date: Not Specified

Not In Compliance

Violation Reference - HSC

Inspector Comments: Request is approved for installation of Pentair Intelliflo Variable speed pump 3HP with 130 gpm.

Violation Description: Plans have been approved and this correction sheet is a part of the approved plans.

Overall Inspection Comments

- 1- Pump has to be locked at a speed that provides flow rate of 92.0 gpm.
- 2- The variable speed pump control pad must be password protected to prevent tampering.
- 3- Flow meter shall be functioning, accurate and readable.
- 4- The district health inspectors will verify these flow rates at each routine inspection.

Surface Area: 800 square feet

Capacity: 33,000 gallon

Flow Rate: 92.0 gpm

Main Drain Suction Line: 2 1/2" with 119 gpm at 8 fps

Skimmer Suction Line: 2 1/2" 119 gpm at 8 fps

Return Line: 2" with 105 gpm at 10 fps

Main drain and equalizer line covers: Paramount SDX

Filter: Hayward DE Pro-Frid 72 with 144 gpm

Proposed Pump: Pentair Intelliflo Variable speed pump 3HP, 130 gpm

Photo Attachments:

No Photo Attachments