



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME MERITAGE @ VICTORIA ARBORS				DATE 4/9/2014	SIGNATURE
LOCATION 7922 DAY CREEK, RANCHO CUCAMONGA, CA 91739				REINSPECTION DATE Not Specified	PERMIT EXPIRATION
MAILING ADDRESS 1151 N DEL RIO PL ONTARIO, CA 91764				REHS Bennetta Betbadal	
FA # FA0014465	PR # Not Specified	SR # SR0063070	CO # Not Specified	PE 3755	PROGRAM IDENTIFIER: None
TIME IN 10:00 AM	TIME OUT 10:15 AM	CONTACT Not Captured			SERVICE: 025 - PLAN REVIEW
				RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
				ACTION: 55 - PLANS APPROVED	

RECREATIONAL HEALTH PLAN CHECK - PLAN CHECK REC HEALTH CONSULTATIO

37K980 Plans - Plan Review Approved

Compliance Date: Not Specified

Not In Compliance

Violation Reference - HSC

Inspector Comments: Request is approved for installation of Pentair Intelliflo Variable speed pump 3HP with 130 gpm.

Violation Description: Plans have been approved and this correction sheet is a part of the approved plans.

Overall Inspection Comments

- 1- Pump has to be locked at a speed that provides flow rate of 84.0 gpm.
- 2- The variable speed pump control pad must be password protected to prevent tampering.
- 3- Flow meter shall be functioning, accurate and readable.
- 4- The district health inspectors will verify these flow rates at each routine inspection.

Surface Area: 96 square feet

Capacity: 2,550 gallon

Flow Rate: 84.0 gpm

Main Drain Suction Line: 2 1/2" with 119 gpm at 8 fps

Skimmer Suction Line: 2 1/2" with 119 gpm at 8 fps

Return Line: 2" with 105 gpm at 10 fps

Main drain and equalizer line covers: aquaStar 10AV101 with 206 gpm

Filter: Pentair FNS-60 with 120 gpm

Proposed Pump: Pentair Intelliflo Variable speed pump 3HP, 130 gpm

Photo Attachments:

No Photo Attachments