



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME TERRACE HILLS JR HIGH SCHOOL				DATE 4/9/2014	SIGNATURE <i>John Babalola</i>
LOCATION 22579 DE BERRY ST, GRAND TERRACE, CA 92313				REINSPECTION DATE 10/09/2014	PERMIT EXPIRATION
MAILING ADDRESS 1212 VALENCIA DR, COLTON CA 92324				REHS John Babalola	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: None	
FA # FA0006398	PR # PR0018205	SR # Not Specified	CO # Not Specified	PE 3603	SERVICE: 001 - INSPECTION - ROUTINE
TIME IN 9:47 AM	TIME OUT 10:48 AM	CONTACT Not Captured			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

98

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K454 Maintenance - Cleanliness

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Black algae and yellow stains buildup observed on the pool shell bottom.
	Not In Compliance	
	Violation Reference - CCR - 65533	

Violation Description: Floating scum, sputum or debris shall not be allowed to accumulate in the pool. The bottom and sides of the pool shall be cleaned as often as necessary to be kept in a clean condition. The sides and bottom of pools, decks and other surfaces shall be kept free of slime and algae.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments