



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN				DATE 4/3/2014	SIGNATURE	
LOCATION 2155 E CONVENTION CENTER WY, ONTARIO, CA 91764				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 1/31/2015	
MAILING ADDRESS 2155 E CONVENTION CENTER WY, ONTARIO CA 91764				REHS Chaz Harrison		
FA # FA0016023	PR # PR0021308	SR # Not Specified	CO # Not Specified	PE 3605	PROGRAM IDENTIFIER: SPA	
TIME IN 2:51 PM	TIME OUT 3:21 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
				RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
				ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - PUBLIC SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

88

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	104.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	2,200
area (sq ft)	79
occupancy	8

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed pH level above 8.0. Ensure to bring pH level between 7.2-8.0. Use Muriatic Acid to decrease the Total Alkalinity of pool.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Corrected on Site.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K420 Temperature - Critical - Spa Water Requirement

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed spa at 106F. Ensure spa temperature does not exceed 104F.
	Not In Compliance	
	Violation Reference - CCR 24 - 3138B	

Corrected on site.

Violation Description: The allowable water temperature of a spa pool shall not exceed 104°F.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments