



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>EQUITY RESIDENTIAL APARTMENTS</b>					DATE <b>4/10/2014</b>	SIGNATURE	
LOCATION <b>955 DUESENBURG DR, ONTARIO, CA 91764-64</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION	
MAILING ADDRESS <b>1151 N DEL RIO PL, ONTARIO, CA 91764</b>					REHS <b>Bennetta Betbadal</b>		
FA # <b>FA0014980</b>	PR # <b>Not Specified</b>	SR # <b>SR0063062</b>	CO # <b>Not Specified</b>	PE <b>3755</b>	PROGRAM IDENTIFIER: <b>None</b>		
TIME IN <b>4:45 PM</b>	TIME OUT <b>5:00 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>025 - PLAN REVIEW</b>		
					RESULT: <b>01 - CORRECTIVE ACTION NOT REQUIRED</b>		
					ACTION: <b>55 - PLANS APPROVED</b>		

**RECREATIONAL HEALTH PLAN CHECK - PLAN CHECK REC HEALTH CONSULTATIO**

**37K980 Plans - Plan Review Approved**

Compliance Date: **Not Specified**

Not In Compliance

Violation Reference - **HSC**

Inspector Comments: Request is approved for installation of Pentair Intelliflo Variable speed pump 3HP with 130 gpm.

Pool

Violation Description: Plans have been approved and this correction sheet is a part of the approved plans.

**Overall Inspection Comments**

- 1- Pump has to be locked at a speed that provides flow rate of 116.0 gpm.
- 2- The variable speed pump control pad must be password protected to prevent tampering.
- 3- Flow meter shall be functioning, accurate and readable.
- 4- The district health inspectors will verify these flow rates at each routine inspection.

Surface Area: 1,400 square feet

Capacity: 42,000 gallon

Flow Rate: 116.0 gpm

Main Drain Suction Line: 3" with 184 gpm at 8 fps

Skimmer Suction Line: 3" 184 gpm at 8 fps

Return Line: 2 1/2" with 149 gpm at 10 fps

Main Drain covers: Paramount SDX

Equalizer Covers: aquaStar 8AV101 with 88 gpm

Filter: Pentair Triton TR140C with 140 gpm

Proposed Pump: Pentair Intelliflo Variable speed pump 3HP, 130 gpm

**Photo Attachments:**

No Photo Attachments