



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME EQUITY RESIDENTIAL APARTMENTS					DATE 4/10/2014	SIGNATURE	
LOCATION 955 DUESENBERG DR, ONTARIO, CA 91764-64					REINSPECTION DATE Not Specified	PERMIT EXPIRATION	
MAILING ADDRESS 1151 N DEL RIO PL, ONTARIO, CA 91764					REHS Bennetta Betbadal		
FA # FA0014980	PR # Not Specified	SR # SR0063063	CO # Not Specified	PE 3755	PROGRAM IDENTIFIER: None		
TIME IN 5:00 PM	TIME OUT 5:15 PM	CONTACT Not Captured			SERVICE: 025 - PLAN REVIEW		
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
					ACTION: 55 - PLANS APPROVED		

RECREATIONAL HEALTH PLAN CHECK - PLAN CHECK REC HEALTH CONSULTATIO

37K980 Plans - Plan Review Approved

Compliance Date: **Not Specified**

Not In Compliance

Violation Reference - **HSC**

Inspector Comments: Request is approved for installation of Pentair Intelliflo Variable speed pump 3HP with 130 gpm.

Spa

Violation Description: Plans have been approved and this correction sheet is a part of the approved plans.

Overall Inspection Comments

- 1- Pump has to be locked at a speed that provides flow rate of 94.0 gpm.
- 2- The variable speed pump control pad must be password protected to prevent tampering.
- 3- Flow meter shall be functioning, accurate and readable.
- 4- The district health inspectors will verify these flow rates at each routine inspection.

Surface Area: 150 square feet

Capacity: 2,812 gallon

Flow Rate: 94.0 gpm

Main Drain Suction Line: 2 1/2" with 119 gpm at 8 fps

Skimmer Suction Line: 2 1/2" 119 gpm at 8 fps

Return Line: 2 1/2" with 149 gpm at 10 fps

Main Drain covers: AquaStar 10AV101 with 206 gpm

Boster Jet Suction Line and Equalizer Line Covers: Paramount SDX

Filter: not provided

Proposed Pump: Pentair Intelliflo Variable speed pump 3HP, 130 gpm

Photo Attachments:

No Photo Attachments