



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME MONTECITO APARTMENTS				DATE 4/11/2014	SIGNATURE	
LOCATION 11343 MOUNTAIN VIEW DR, RANCHO CUCAMONGA, CA 91730				REINSPECTION DATE Not Specified	PERMIT EXPIRATION	
MAILING ADDRESS 1151 N DEL RIO PL ONTARIO, CA 91764				REHS Bennetta Betbadal		
FA # FA0004465	PR # Not Specified	SR # SR0063000	CO # Not Specified	PE 3755	PROGRAM IDENTIFIER: None	
TIME IN 5:00 PM	TIME OUT 5:15 PM	CONTACT Not Captured			SERVICE: 025 - PLAN REVIEW	
				RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
				ACTION: 55 - PLANS APPROVED		

RECREATIONAL HEALTH PLAN CHECK - PLAN CHECK REC HEALTH CONSULTATIO

37K980 Plans - Plan Review Approved

Compliance Date: **Not Specified**

Not In Compliance

Violation Reference - **HSC**

Inspector Comments: Request is approved for installation of Pentair Intelliflo Variable speed pump 1HP with 76 gpm.

South-East Spa

Violation Description: Plans have been approved and this correction sheet is a part of the approved plans.

Overall Inspection Comments

- 1- Pump has to be locked at a speed that provides flow rate of 59.0 gpm.
- 2- The variable speed pump control pad must be password protected to prevent tampering.
- 3- Flow meter shall be functioning, accurate and readable.
- 4- The district health inspectors will verify these flow rates at each routine inspection.

Surface Area: 96 square feet

Capacity: 1,780 gallon

Flow Rate: 59.0 gpm

Main Drain Suction Line: 2" with 84 gpm at 8 fps

Skimmer Suction Line: 2" with 84 gpm at 8 fps

Return Line: 2" with 105 gpm at 10 fps

Main drain and equalizer line covers: Paramount SDX

Filter: Pentair FNS-Plus 48 with 99 gpm

Proposed Pump: Pentair Intelliflo Variable speed pump 1HP, 76gpm

Photo Attachments:

No Photo Attachments