



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME REDLANDS EAST VALLEY HIGH SCHOOL					DATE 4/11/2014	SIGNATURE	
LOCATION 3100 E COLTON AV, MENTONE, CA 92374					REINSPECTION DATE 10/11/2014	PERMIT EXPIRATION	
MAILING ADDRESS 3100 E COLTON AV, MENTONE, CA 92374					REHS Antonio Fields		
FA # FA0000782	PR # PR0015855	SR # Not Specified	CO # Not Specified	PE 3603	PROGRAM IDENTIFIER: pool		
TIME IN 12:38 PM	TIME OUT 1:00 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		




RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE



temperature (F)	No Data
observed flow (gpm)	869
required flow (gpm)	833
volume (gal)	300,000
area (sq ft)	No Data
occupancy	No Data

36K438 Enclosure - Critical - Gates Drowning Hazard



POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed 1 or 2 gates unable to self-closed. Ensure gates are self-closing and self-latching. Corrected during the inspection.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed the daily records not maintained. Maintain a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

Overall Inspection Comments

Influent Pressure: 10 psi

Maintain the safety signs in good repair.

Minimum required flow rate: 633 gpm

Photo Attachments:

No Photo Attachments