



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>FRIENDLY HILLS M EST LLC</b>				DATE <b>4/15/2014</b>	SIGNATURE	
LOCATION <b>2140 S MENTONE BL, CA 92359</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION	
MAILING ADDRESS <b>495 E INDUSTRIAL RD SAN BERNARDINO, CA 92408</b>				REHS <b>Hui Chieng</b>		
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: None		
FA # <b>FA0007184</b>	PR # <b>Not Specified</b>	SR # <b>SR0062966</b>	CO # <b>Not Specified</b>	PE <b>3716</b>	SERVICE: 025 - PLAN REVIEW	
TIME IN <b>2:00 PM</b>	TIME OUT <b>2:45 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
				ACTION: 55 - PLANS APPROVED		

**RECREATIONAL HEALTH PLAN CHECK - PLNCK POOL MINOR REMODEL - ALL**

**37K980 Plans - Plan Review Approved**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:** The proposed plans to remodel the existing pool facility has been approved.  
  
Scope of remodel: replace drain covers with Pentair SDX; split main drains & equalizer drains; replace existing skimmers; new hand rail and replaster.

**Violation Description:** Plans have been approved and this correction sheet is a part of the approved plans.

**37K501 Equipment – Pump – Variable Speed**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR 24 - 3125.B.1

**Inspector Comments:** The variable speed pump was stated to be locked at 120 gpm. This flow rate exceeds the stated pipe velocity(2 inch suction = 84 gpm @ 8fps).  
  
Further investigation shall be conducted during the field inspection to determine the proper flow rate.

**Violation Description:** The variable speed pump must be locked by the installer at the approved rate of flow.

**37K512 Remodel – Equipment**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - Reference Number - SBC Policy

**Inspector Comments:**

**Violation Description:** Existing pool equipment is subject to final approval by EHS, as determined at the time of the field inspections.

**Overall Inspection Comments**

Please schedule a pre-plaster inspection in advance by contacting Environmental Health Services at 800-442-2283.

Ensure split pipe lines are exposed for inspection.

**Photo Attachments:**  
No Photo Attachments