



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>COMFORT INN &amp; SUITES</b>				DATE <b>4/17/2014</b>	SIGNATURE 
LOCATION <b>450 N SPERRY DR, COLTON, CA 92324</b>				REINSPECTION DATE <b>10/17/2014</b>	PERMIT EXPIRATION <b>5/31/2014</b>
MAILING ADDRESS <b>2512 FOOTHILL BL, SAN BERNARDINO CA 92410</b>				REHS <b>John Babalola</b>	
FA # <b>FA0019492</b>	PR # <b>PR0026641</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool
TIME IN <b>10:41 AM</b>	TIME OUT <b>11:39 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

**RECREATIONAL HEALTH - PUBLIC POOL**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**84**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	0
required flow (gpm)	80
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant**



<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	Inspector Comments: The free chlorine level is observed at 0.0 ppm. Provide at least 1.5 ppm.
	Not In Compliance	Note: Correction is being made.
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: The cyanuric acid level is observed above 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Repair/replace the non-functional flow meter.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K458 Maintenance - Test Kit/Daily Records**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: No daily records of pH and chlorine readings observed.
	Not In Compliance	Provide a DPD test kit. OTO test kit is not acceptable.
	Violation Reference - CCR - 65523, 65529	

**Violation Description:** Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>COMFORT INN &amp; SUITES</b>	DATE <b>4/17/2014</b>	SIGNATURE 
LOCATION 450 N SPERRY DR, COLTON, CA 92324		REHS <b>John Babalola</b>

### 36K460 Skimmers - Requirements

<b>POINTS</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 65533, 3136B	<b>Inspector Comments:</b> Repair the non-functional skimmers.
---------------	---	--

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

### 36K466 Structure - Pool Shell

<b>POINTS</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3108B	<b>Inspector Comments:</b> Yellow stains and debris buildup observed on the pool shell bottom.
---------------	--	--

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

### 36K472 Access - Steps - Handrails - Diving Area

<b>POINTS</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3111B, 3113B	<b>Inspector Comments:</b> Secure the unstable hand rails.
---------------	---	--

**Violation Description:** Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.

### Overall Inspection Comments

No summary comments have been made for this inspection.

**Photo Attachments:**  
No Photo Attachments