



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME MCDONALD'S				DATE 4/23/2014	SIGNATURE
LOCATION 10143 SIERRA AV, FONTANA, CA 92335				REINSPECTION DATE 4/25/2014	PERMIT EXPIRATION 6/30/2014
MAILING ADDRESS 10143 SIERRA AV, FONTANA, CA 92335				REHS Amanda Gaspard	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: None	
FA # FA0009702	PR # PR0002529	SR # Not Specified	CO # Not Specified	PE 1621	SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
TIME IN 11:06 AM	TIME OUT 11:25 AM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIR
					ACTION: 03 - REINSPECTION REQUIRED

RETAIL FOOD PROTECTION - PUBLIC EATING PL (25-99 SEATS)

16K994 Reinspection

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: During the routine inspection on 4-18-14, observed the following water temperature violations:

- 1) Water at 82F at the handwashing sink in the men's restroom.
- 2) Water at 74F at the handwashing sink in the women's restroom.
- 3) Water at 78F at the handwashing sink in the front service area (near the cash registers).

Facility was told to ensure that warm water (100F or above) is available at all handwashing sinks. Facility was told to correct violation within 48 hours.

During the re-inspection on 4-23-14, observed the following water temperature violations:

- 1) Water at 78F at the handwashing sink in the men's restroom. (This was the highest water temperature measured at this sink; the temperature dropped down to 76F while measuring water temperature).
- 2) Water at 80F at the handwashing sink in the women's restroom. (Temperature at this handwashing sink also began to drop while measuring water temperature.)
- 3) Water at 71F at the handwashing sink in the front service area (near the cash registers).

Ensure that water temperature requirements are met at all handwashing sinks within 48 hours. Inspector will conduct a billable re-re-inspection after 48 hours to determine compliance.

(Note: facility had hot water at time of this inspection. Temp'ed water at 123F at the handwashing sink near the ice machine.)

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Ensure that water temperature requirements are met at all handwashing sinks within 48 hours. Inspector will conduct a billable re-re-inspection after 48 hours to determine compliance.

Photo Attachments:
No Photo Attachments